

Pressure Vessel Engineering, Ltd.
120 Randall Dr. Waterloo, Ontario N2V 1C6

Date Printed: 11/20/2008

CUSTOMER

Pressure Vessel Engineering
120 Randall Drive, Suite 'B'
Waterloo, Ontario N2V 1C6

VESSEL LOCATION

Pressure Vessel Engineering
Vessel With Large Opening
Sample Vessel 5

Vessel designed per the ASME Boiler & Pressure Vessel Code,
Section VIII, Division 1, 2007 Edition
with Advanced Pressure Vessel, Version: 10.0.2
Vessel is ASME Code Stamped

Job No: PVE-Sample5
Vessel Number: Sample Vessel 5

NAMEPLATE INFORMATION

Vessel MAWP: 200.00 PSI at 350 °F
MDMT: -20 °F at 200.00 PSI

Serial Number(s): _____

National Board Number(s): _____

Year Built: 2007

Radiography: NONE

Postweld Heat Treated: NONE

Construction Type: W

Notes

2" FERRULE CRN ASLOA 7213.51246089
8" FERRULE PROOF TESTED TO UG-101(m)

Signatures

P.Eng: _____ Date: ____/____/____

Laurence Brundrett

Mechanical Technologist: _____ Date: ____/____/____



Ben Vanderloo

Table of Contents

Outlet 8" Ferrule Nozzle D	1
Shell 2 - thin shell	2
thick shell	3
Conical Reducer 1	4
10" Inlet Nozzle C	5
2" Inlet Nozzle A	10
2"3000# Cplg N-E	13
2" Heavy Ferrule Nozzle B	16
10" Inlet Flange	19
Cover Flange	23
ASME Flanges	25
Cone to Cylinder 1	26
Cone to Cylinder 2	27
Cone to Cylinder 3	28
MDMT Summary	29
MAWP Summary	30
Summary Information	31

Pressure Vessel Engineering, Ltd.
120 Randall Dr. Waterloo, Ontario N2V 1C6

Date Printed: 11/20/2008



Pressure Vessel Engineering, Ltd.

Outlet 8" Ferrule Nozzle D

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5
Number: 1

Vessel Number: Sample Vessel 5
Mark Number: N-D

Date Printed: 11/20/2008

Cylindrical Shell Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Long. Joint Efficiency:	85 %
Shell Material:	SA-479 304, High	Factor B Chart:	HA-1
Shell Length:	1.1020 in.	Material Stress (hot):	18600 PSI
Corrosion Allowance:	0.0000 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Compressive Stress:	9170 PSI
Outside Diameter (new):	8.0300 in.	Actual Circumferential Stress:	12078 PSI
Outside Diameter (corroded):	8.0300 in.	Actual Longitudinal Stress:	7189 PSI
Shell Surface Area:	0.19 Sq. Ft.	Specific Gravity:	1.00
Shell Estimated Volume:	0.23 Gal.	Weight of Fluid:	1.94 lb.
Circ. Joint Efficiency:	70 %	Total Flooded Shell Weight:	2.56 lb.
		Shell Weight:	0.62 lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material exempt from impact testing per UCS-66(b), stress ratio <= 0.35

Design Thickness Calculations

Longitudinal Stress Calculations per Paragraph UG-27(c)(2)

$$t = \frac{PR}{2SE + 0.4P} = \frac{201.00 * 3.9370}{2 * 18600 * 0.70 + 0.4 * 201.00}$$

= Greater Of (0.0303(Calculated), 0.0625(Minimum Allowed) + 0.0000 (corrosion) + 0.0000 (ext. corrosion) = minimum of **0.0625 in.**

Circumferential Stress Calculations per Appendix 1-1(a)(1)

$$t = \frac{PR_o}{SE + 0.4P} = \frac{201.00 * 4.0150}{18600 * 0.85 + 0.4 * 201.00}$$

= Greater of (0.0508(Calculated), 0.0625(Minimum Allowed) + 0.0000 (corrosion) + 0.0000 (ext. corrosion) = minimum of **0.0625 in.**

Extreme Fiber Elongation Calculation per Paragraph UHA-44

$$\text{Elongation} = \frac{50t}{R_f} = \frac{50 * 0.0780}{3.9760} = \text{elongation of } \mathbf{0.98 \%}$$

Nominal Shell Thickness Selected = **0.0780 in.**

Pressure Vessel Engineering, Ltd.

Shell 2 - thin shell

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5
Number: 2

Vessel Number: Sample Vessel 5
Mark Number: S2

Date Printed: 11/20/2008

Cylindrical Shell Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Long. Joint Efficiency:	70 %
Shell Material:	SA-240 304, High	Factor B Chart:	HA-1
		Material Stress (hot):	18600 PSI
Shell Length:	15.5000 in.	Material Stress (cold):	20000 PSI
		Compressive Stress:	10102 PSI
Corrosion Allowance:	0.0000 in.	Actual Circumferential Stress:	9622 PSI
External Corrosion Allowance:	0.0000 in.	Actual Longitudinal Stress:	4667 PSI
Outside Diameter (new):	12.7500 in.		
Outside Diameter (corroded):	12.7500 in.	Specific Gravity:	1.00
Shell Surface Area:	4.31 Sq. Ft.	Weight of Fluid:	67.42 lb.
Shell Estimated Volume:	8.07 Gal.	Total Flooded Shell Weight:	100.77 lb.
Circ. Joint Efficiency:	70 %	Shell Weight:	33.35 lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material exempt from impact testing per UCS-66(b), stress ratio <= 0.35

Design Thickness Calculations

Longitudinal Stress Calculations per Paragraph UG-27(c)(2)

$$t = \frac{PR}{2SE + 0.4P} = \frac{201.00 * 6.1870}{2 * 18600 * 0.70 + 0.4 * 201.00}$$

= Greater Of (0.0476(Calculated), 0.0625(Minimum Allowed)) + 0.0000 (corrosion) + 0.0000 (ext. corrosion) = minimum of **0.0625** in.

Circumferential Stress Calculations per Appendix 1-1(a)(1)

$$t = \frac{PR_o}{SE + 0.4P} = \frac{201.00 * 6.3750}{18600 * 0.70 + 0.4 * 201.00} = 0.0979 + 0.0000 (corrosion) + 0.0000 (ext. corrosion) = \text{minimum of } \mathbf{0.0979} \text{ in.}$$

Extreme Fiber Elongation Calculation per Paragraph UHA-44

$$\text{Elongation} = \frac{50t}{Rf} = \frac{50 * 0.1880}{6.2810} = \text{elongation of } \mathbf{1.50} \%$$

Nominal Shell Thickness Selected = **0.1880** in.

Pressure Vessel Engineering, Ltd.

thick shell

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5
Number: 3

Vessel Number: Sample Vessel 5
Mark Number: S3

Date Printed: 11/20/2008

Cylindrical Shell Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Long. Joint Efficiency:	85 %
Shell Material:	SA-312 TP304 SMLS, High	Factor B Chart:	HA-1
Shell Length:	4.5000 in.	Material Stress (hot):	18600 PSI
Corrosion Allowance:	0.0000 in.	Material Stress (cold):	20000 PSI
External Corrosion Allowance:	0.0000 in.	Compressive Stress:	11376 PSI
Outside Diameter (new):	12.7500 in.	Actual Circumferential Stress:	2413 PSI
Outside Diameter (corroded):	12.7500 in.	Actual Longitudinal Stress:	1301 PSI
Shell Surface Area:	1.25 Sq. Ft.	Specific Gravity:	1.00
Shell Estimated Volume:	1.98 Gal.	Weight of Fluid:	16.54 lb.
Circ. Joint Efficiency:	70 %	Total Flooded Shell Weight:	50.52 lb.
		Shell Weight:	33.98 lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Material is exempt from impact testing per UHA-51(d)

Design Thickness Calculations

Longitudinal Stress Calculations per Paragraph UG-27(c)(2)

$$t = \frac{PR}{2SE + 0.4P} = \frac{201.00 * 5.6880}{2 * 18600 * 0.70 + 0.4 * 201.00}$$

= Greater Of (0.0438(Calculated), 0.0625(Minimum Allowed)) + 0.0000 (corrosion) + 0.0000 (ext. corrosion) + 0.0859 (12 1/2% for pipe)
= minimum of **0.1484 in.**

Circumferential Stress Calculations per Appendix 1-1(a)(1)

$$t = \frac{PR_o}{SE + 0.4P} = \frac{201.00 * 6.3750}{18600 * 0.85 + 0.4 * 201.00} = 0.0807 + 0.0000 (corrosion) + 0.0000 (ext. corrosion) + 0.0859 (12 1/2% for pipe)$$

= minimum of **0.1666 in.**

Pipe Selected: Size = **12 in.**, Schedule = **80**, Diameter = **12.7500 in.**, Wall = **0.6870 in.**

Pressure Vessel Engineering, Ltd.

Conical Reducer 1

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5
Number: 1

Vessel Number: Sample Vessel 5
Mark Number: R1

Date Printed: 11/20/2008

Conical Reducer Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Joint Efficiency:	70 %
Conical Reducer Material:	SA-240 304, High	Factor B Chart:	HA-1
Corrosion Allowance:	0.0000 in.	Material Stress (hot):	18600 PSI
External Corrosion Allowance:	0.0000 in.	Material Stress (cold):	20000 PSI
Small End of Cone Located at:	Bottom	Actual Conical Reducer Stress:	10681 PSI
Outside Diameter :	12.7500 in.	Outside Ds :	8.0300 in.
angle a (α):	25.27 °	Cone Height (h) :	4.9994 in.
Conical Reducer Surface Area:	1.25 Sq. Ft.	Specific Gravity:	1.00
Conical Reducer Estimated Volume:	1.72 Gal.	Weight of Fluid:	14.37 lb.
Conical Reducer Weight:	9.62 lb.	Total Flooded Conical Reducer Weight:	23.99 lb.

Minimum Design Metal Temperature Data

Minimum Design Metal Temperature: -20 °F
Other Exemption

Design Thickness Calculations

Design Thickness Calculations per Appendix 1-4(e)

$$t = \frac{PD_o}{2 \cos \alpha(SE + 0.4P)} = \frac{201.00 * 12.7500}{2 * 0.9043 * (18600 * 0.70 + 0.4 * 201.00)} = 0.1082 + 0.0000 \text{ (corrosion)} + 0.0000 \text{ (ext. corrosion)}$$

= minimum of **0.1082 in.**

Extreme Fiber Elongation Calculation per Paragraph UHA-44

$$\text{elongation} = \frac{50t}{R_f} = \frac{50 * 0.1875}{3.9213} = \text{elongation of } \mathbf{2.39 \%}$$

Nominal Conical Reducer Thickness Selected = **0.1875 in.**

Pressure Vessel Engineering, Ltd.

10" Inlet Nozzle C

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 1

ID Number: N-C

Vessel Number: Sample Vessel 5

Mark Number: N-C

Date Printed: 11/20/2008

Nozzle Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Nozzle Efficiency (E):	85 %
Nozzle Material:	SA-312 TP304 SMLS, High	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	HA-1
External Projection:	4.0000 in.	Allowable Stress at Design Temperature (S _n):	18600 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0000 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	10	Nozzle Pipe Schedule:	40
Nozzle ID (new):	10.0200 in.	Nozzle Wall Thickness(new):	0.3650 in.
Nozzle ID (corroded):	10.0200 in.	Nozzle Wall Thickness(corroded):	0.3650 in.
Outer "h" Limit:	0.4700 in.	Upper Weld Leg Size(Weld 41):	0.2500 in.
Internal "h" Limit:	0.4700 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
OD, Limit of Reinforcement:	20.0400 in.	Appendix 1-7 OD, Limit of Reinforcement(d _{LDR}):	15.0300 in.
Outside Groove Weld Depth:	0.1880 in.		

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F

Material exempt from impact testing per UCS-66(b), stress ratio <= 0.35

Host Component: Shell 2 - Shell 2 - thin shell

Material:	SA-240 304, High	Shell wall thickness(new):	0.1880 in.
Material Stress(S _v):	18600 PSI	Shell wall thickness(corroded):	0.1880 in.

Nozzle Detail Information




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.2500 in.

Nozzle Wall Thickness(t_n): 0.3650 in.

Outside Groove Weld Depth: 0.1880 in.

Nozzle passes through the vessel, attached by a groove weld.

Pipe Size: 10 Schedule: 40

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Large opening meets Appendix 1-7 stress calculation requirements

Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

10" Inlet Nozzle C

Job No: PVE-Sample5
Number: 1
ID Number: N-C

Vessel Number: Sample Vessel 5
Mark Number: N-C

Date Printed: 11/20/2008

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{PR_o}{SE + 0.4P} = \frac{201.00 * 6.3750}{18600 * 1 + 0.4 * 201.00} = \mathbf{0.0686 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{PR_n}{SE - 0.6P} = \frac{201.00 * 5.0100}{18600 * 1 - 0.6 * 201.00} = \mathbf{0.0545 \text{ in.}}$$

Strength Reduction Factors

$$fr1 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000 \quad fr2 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000$$

$$fr3 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PR_n}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{201.00 * 5.0100}{18600 * 0.85 - 0.6 * 201.00} + 0.0000 + 0.0000 = \mathbf{0.0642 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{PR_o}{SE + 0.4P} + Ca + \text{ext. Ca} = \frac{201.00 * 6.3750}{18600 * 1 + 0.4 * 201.00} + 0.0000 + 0.0000 = \mathbf{0.0686 \text{ in.}}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + Ca + \text{ext. Ca} = \mathbf{0.3194 \text{ in.}}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = \mathbf{0.0686 \text{ in.}}$$

Wall thickness = $t_n * 0.875(\text{pipe}) = \mathbf{0.3194}$ is greater than or equal to UG-45 value of $\mathbf{0.0686}$

Pressure Vessel Engineering, Ltd.

10" Inlet Nozzle C

Job No: PVE-Sample5
Number: 1
ID Number: N-C

Vessel Number: Sample Vessel 5
Mark Number: N-C

Date Printed: 11/20/2008

Nozzle Reinforcement Calculations

Area Required for Internal Pressure

$$A = d \text{ tr } F + 2 \text{ tn tr } F (1 - fr1) = (10.0200 * 0.0686 * 1.00) + (2 * 0.3650 * 0.0686 * 1.00 * (1 - 1.0000)) = \mathbf{0.6874 \text{ sq. in.}}$$

Area Available - Internal Pressure

$$A1 \text{ Formula 1} = d(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = 10.0200 * (1.00 * 0.1880 - 1.00 * 0.0686) - 2 * 0.3650 * (1.00 * 0.1880 - 1.00 * 0.0686) * (1 - 1.0000) = 1.1964 \text{ sq. in.}$$

$$A1 \text{ Formula 2} = 2(t + \text{tn})(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = 2 * (0.1880 + 0.3650)(1.00 * 0.1880 - 1.00 * 0.0686) - 2 * 0.3650 * (1.00 * 0.1880 - 1.00 * 0.0686) * (1 - 1.0000)$$

$$= 0.1321 \text{ sq. in.}$$

$$A1 = \text{Larger value of } A1 \text{ Formula 1 and } A1 \text{ Formula 2} = \mathbf{1.1964 \text{ sq. in.}}$$

$$A2 \text{ Formula 1} = 5(\text{tn} - \text{trn}) \text{ fr2 t} = 5(0.3650 - 0.0545) * 1.0000 * 0.1880 = 0.2919 \text{ sq. in.}$$

$$A2 \text{ Formula 2} = 5(\text{tn} - \text{trn}) \text{ fr2 tn} = 5(0.3650 - 0.0545) * 1.0000 * 0.3650 = 0.5667 \text{ sq. in.}$$

$$A2 = \text{Smaller value of } A2 \text{ Formula 1 and } A2 \text{ Formula 2} = \mathbf{0.2919 \text{ sq. in.}}$$

A3 = Smaller value of the following :

$$5 * t * t_i * fr2 = 5 * 0.1880 * 0.3650 * 1.0000 = 0.3431 \text{ sq. in.}$$

$$5 * t_i * t_i * fr2 = 5 * 0.3650 * 0.3650 * 1.0000 = 0.6661 \text{ sq. in.}$$

$$2 * h * t_i * fr2 = 2 * 0.0000 * 0.3650 * 1.0000 = 0.0000 \text{ sq. in.}$$

$$= \mathbf{0.0000 \text{ sq. in.}}$$

$$A41 = (\text{leg})^2 * fr2 = (0.2500)^2 * 1.0000$$

$$= \mathbf{0.0625 \text{ sq. in.}}$$

$$A43 = (\text{leg})^2 * fr2 = 0 * 1.0000$$

$$= \mathbf{0.0000 \text{ sq. in.}}$$

$$\mathbf{Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A43 = 1.5508 \text{ sq. in., which is greater than } A (0.6874)}$$

Pressure Vessel Engineering, Ltd.

10" Inlet Nozzle C

Job No: PVE-Sample5
Number: 1
ID Number: N-C

Vessel Number: Sample Vessel 5
Mark Number: N-C

Date Printed: 11/20/2008

Appendix 1-7(a) (Large Opening in Shell) Calculations

Area Required for Internal Pressure

$$A = \frac{2}{3} * (d \text{ tr } F + 2 \text{ tn tr } F (1 - fr1)) = \frac{2}{3} * ((10.0200 * 0.0686 * 1.00) + (2 * 0.3650 * 0.0686 * 1.00 * (1 - 1.0000))) = \mathbf{0.4583} \text{ sq. in.}$$

Area Available - Internal Pressure

$$A1 = (d_{LDR} - d)(E1 \text{ t} - F \text{ tr}) - 2\text{tn}(E1 \text{ t} - F \text{ tr})(1 - fr1) = (15.0300 - 10.0200) * (1.00 * 0.1880 - 1.00 * 0.0686) - 2 * 0.3650 * (1.00 * 0.1880 - 1.00 * 0.0686) * (1 - 1.0000) = \mathbf{0.5982} \text{ sq. in.}$$

$$A2 \text{ Formula 1} = 5(\text{tn} - \text{trn}) \text{ fr2 t} = 5(0.3650 - 0.0545) * 1.0000 * 0.1880 = 0.2919 \text{ sq. in.}$$

$$A2 \text{ Formula 2} = 5(\text{tn} - \text{trn}) \text{ fr2 tn} = 5(0.3650 - 0.0545) * 1.0000 * 0.3650 = 0.5667 \text{ sq. in.}$$

$$A2 = \text{Smaller value of } A2 \text{ Formula 1 and } A2 \text{ Formula 2} = \mathbf{0.2919} \text{ sq. in.}$$

A3 = Smaller value of the following :

$$5 * t * t_i * f_{r2} = 5 * 0.1880 * 0.3650 * 1.0000 = 0.3431 \text{ sq. in.}$$

$$5 * t_i * t_i * f_{r2} = 5 * 0.3650 * 0.3650 * 1.0000 = 0.6661 \text{ sq. in.}$$

$$2 * h * t_i * f_{r2} = 2 * 0.0000 * 0.3650 * 1.0000 = 0.0000 \text{ sq. in.}$$

$$= \mathbf{0.0000} \text{ sq. in.}$$

$$A41 = (\text{leg})^2 * fr2 = (0.2500)^2 * 1.0000 = \mathbf{0.0625} \text{ sq. in.}$$

$$A43 = (\text{leg})^2 * fr2 = 0 * 1.0000 = \mathbf{0.0000} \text{ sq. in.}$$

Area Available (Internal Pressure) = A1 + A2 + A3 + A41 + A43 = 0.9526 sq. in., which is **greater** than A (0.4583)

Pressure Vessel Engineering, Ltd.

10" Inlet Nozzle C

Job No: PVE-Sample5
Number: 1
ID Number: N-C

Vessel Number: Sample Vessel 5
Mark Number: N-C

Date Printed: 11/20/2008

Nozzle Weld Strength Calculations

Attachment Weld Strength per Paragraph UW-16

Weld 41 t_{min} = smaller of 0.75, t , or t_n = smaller of 0.75, 0.1880, or 0.3650 = **0.1880 in.**

Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.1316}{0.7}$ = **0.1880 in.**

Weld 41, actual weld leg = **0.2500 in.**

Unit Stresses per Paragraphs UG-45(c) and UW-15

Nozzle wall in shear = $0.70 * S_n = 0.70 * 18600$ = **13020 PSI**

Upper fillet, Weld 41, in shear = $0.49 * \text{Material Stress} = 0.49 * 18600$ = **9114 PSI**

Vessel groove weld, in tension = $0.74 * \text{Material Stress} = 0.74 * 18600$ = **13764 PSI**

Strength of Connection Elements

Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} =$
 $\frac{1}{2} * \pi * 10.3850 * 0.3650 * 13020$ = **77500 lb.**

Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 10.7500 * 0.2500 * 9114$ = **38500 lb.**

Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} =$
 $\frac{1}{2} * \pi * 10.7500 * 0.1880 * 13764$ = **43700 lb.**

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

W = $[A - A_1 + 2 t_n f r_1 (E_1 t - F t r)] S_v = [0.6874 - 1.1964 + 2 * 0.3650 * 1.0000 * (1.00 * 0.1880 - 1.0000 * 0.0686)] * 18600$ = **-7846 lb.**

W1-1 = $(A_2 + A_5 + A_{41} + A_{42}) * S_v = (0.2919 + 0.0000 + 0.0625 + 0.0000) * 18600$ = **6590 lb.**

W2-2 = $(A_2 + A_3 + A_{41} + A_{43} + 2 t_n t f r_1) S_v = (0.2919 + 0.0000 + 0.0625 + 0.0000 + 2 * 0.3650 * 0.1880 * 1.0000) * 18600$ = **9140 lb.**

W3-3 = $(A_2 + A_3 + A_5 + A_{41} + A_{42} + A_{43} + 2 t_n t f r_1) * S_v =$
 $(0.2919 + 0.0000 + 0.0000 + 0.0625 + 0.0000 + 0.0000 + 2 * 0.3650 * 0.1880 * 1.0000) * 18600$ = **9140 lb.**

Check Strength Paths

Path 1-1 = Upper fillet in shear + Nozzle wall in shear = $38500 + 77500$ = **116000 lb.**

Path 2-2 = Upper fillet in shear + Groove weld in tension + Inner fillet in shear =
 $38500 + 43700 + 0$ = **82200 lb.**

Path 3-3 = Upper fillet in shear + Inner fillet in shear + Groove weld in tension = $38500 + 0 + 43700$ = **82200 lb.**

Pressure Vessel Engineering, Ltd.

2" Inlet Nozzle A

Customer: **Pressure Vessel Engineering**
 Job No: PVE-Sample5
 Number: 2
 ID Number: N-A

Vessel Number: Sample Vessel 5
 Mark Number: N-A

Date Printed: 11/20/2008

Nozzle Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Nozzle Efficiency (E):	85 %
Nozzle Material:	SA-312 TP304 SMLS, High	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	HA-1
External Projection:	3.0000 in.	Allowable Stress at Design Temperature (S _n):	18600 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0000 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle Pipe Size:	2	Nozzle Pipe Schedule:	40
Nozzle ID (new):	2.0670 in.	Nozzle Wall Thickness(new):	0.1540 in.
Nozzle ID (corroded):	2.0670 in.	Nozzle Wall Thickness(corroded):	0.1540 in.
Developed Opening:	2.1920 in.	Tangential Dimension L:	7.0000 in.
Outer "h" Limit:	0.3850 in.	Upper Weld Leg Size(Weld 41):	0.1880 in.
Internal "h" Limit:	0.3850 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
OD, Limit of Reinforcement:	4.3840 in.	Outside Groove Weld Depth:	0.1875 in.

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F

Material exempt from impact testing per UCS-66(b), stress ratio <= 0.35

Host Component: Cone 1 - Conical Reducer 1

Material:	SA-240 304, High	Conical Reducer wall thickness(new):	0.1875 in.
Material Stress(S _v):	18600 PSI	Conical Reducer wall thickness - thin out (corroded):	0.1875 in.
Distance from small end of cone:	2.5000 in.	Diameter of Cone at Nozzle:	10.3903 in.

Nozzle Detail Information




Fig. LW-16.1 (c)

Upper Weld Leg Size(Weld 41):	0.1880 in.
Nozzle Wall Thickness(t _n):	0.1540 in.
Outside Groove Weld Depth:	0.1875 in.

tangential to the vessel wall, attached by a groove weld.

Pipe Size: 2 Schedule: 40

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

2" Inlet Nozzle A

Job No: PVE-Sample5
 Number: 2
 ID Number: N-A

Vessel Number: Sample Vessel 5
 Mark Number: N-A

Date Printed: 11/20/2008

Required Conical Reducer Thickness per Paragraph UG-37(a)

$$t_r = \frac{PDo}{(2 * \cos \alpha(SE + 0.4P))} = \frac{201.00 * 10.3903}{(2 * 0.9043 * (18600 * 1 + 0.4 * 201.00))} = \mathbf{0.0618 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{PRn}{SE - 0.6P} = \frac{201.00 * 1.0335}{18600 * 1 - 0.6 * 201.00} = \mathbf{0.0112 \text{ in.}}$$

Strength Reduction Factors

$$fr1 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000 \quad fr2 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000$$

$$fr3 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PRn}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{201.00 * 1.0335}{18600 * 0.85 - 0.6 * 201.00} + 0.0000 + 0.0000 = \mathbf{0.0132 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{PDo}{(2 * \cos \alpha(SE + 0.4P))} + Ca + \text{ext. Ca} = \frac{201.00 * 10.3903}{(2 * 0.9043 * (18600 * 1 + 0.4 * 201.00))} + 0.0000 + 0.0000$$

= Greater Of (0.0618(Calculated), 0.0625(Minimum Allowed)) + 0.0000 (corrosion) + 0.0000 (ext. corrosion) = **0.0625 in.**

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

t = minimum thickness of standard wall pipe + Ca + ext. Ca = **0.1347 in.**

Nozzle Minimum Thickness per Paragraph UG-45(b)

t = Smallest of UG-45(b)(1) or UG-45(b)(4) = **0.0625 in.**

Wall thickness = t_n * 0.875(pipe) = **0.1347** is greater than or equal to UG-45 value of **0.0625**

Pressure Vessel Engineering, Ltd.

2" Inlet Nozzle A

Job No: PVE-Sample5
Number: 2
ID Number: N-A

Vessel Number: Sample Vessel 5
Mark Number: N-A

Date Printed: 11/20/2008

Nozzle Weld Strength Calculations

Attachment Weld Strength per Paragraph UW-16

Weld 41 t_{min} = smaller of 0.75, t , or t_n = smaller of 0.75, 0.1875, or 0.1540 = **0.1540 in.**

Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.1078}{0.7}$ = **0.1540 in.**

Weld 41, actual weld leg = **0.1880 in.**

Unit Stresses per Paragraphs UG-45(c) and UW-15

Nozzle wall in shear = $0.70 * S_n = 0.70 * 18600$ = **13020 PSI**

Upper fillet, Weld 41, in shear = $0.49 * \text{Material Stress} = 0.49 * 18600$ = **9114 PSI**

Vessel groove weld, in tension = $0.74 * \text{Material Stress} = 0.74 * 18600$ = **13764 PSI**

Strength of Connection Elements

Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} = \frac{1}{2} * \pi * 2.2210 * 0.1540 * 13020$ = **6990 lb.**

Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 2.3750 * 0.1880 * 9114$ = **6390 lb.**

Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} = \frac{1}{2} * \pi * 2.3750 * 0.1875 * 13764$ = **9620 lb.**

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

W = $[A - A1 + 2 t_n f r1 (E1t - Ftr)] S_v = [0.1355 - 0.2755 + 2 * 0.1540 * 1.0000 * (1.00 * 0.1875 - 1.0000 * 0.0618)] * 18600$ = **-1883 lb.**

W1-1 = $(A2 + A5 + A41 + A42) * S_v = (0.1100 + 0.0000 + 0.0353 + 0.0000) * 18600$ = **2700 lb.**

W2-2 = $(A2 + A3 + A41 + A43 + 2 t_n t f r1) S_v = (0.1100 + 0.0000 + 0.0353 + 0.0000 + 2 * 0.1540 * 0.1875 * 1.0000) * 18600$ = **3780 lb.**

W3-3 = $(A2 + A3 + A5 + A41 + A42 + A43 + 2 t_n t f r1) * S_v = (0.1100 + 0.0000 + 0.0000 + 0.0353 + 0.0000 + 0.0000 + 2 * 0.1540 * 0.1875 * 1.0000) * 18600$ = **3780 lb.**

Check Strength Paths

Path 1-1 = Upper fillet in shear + Nozzle wall in shear = $6390 + 6990$ = **13380 lb.**

Path 2-2 = Upper fillet in shear + Groove weld in tension + Inner fillet in shear = $6390 + 9620 + 0$ = **16010 lb.**

Path 3-3 = Upper fillet in shear + Inner fillet in shear + Groove weld in tension = $6390 + 0 + 9620$ = **16010 lb.**

Pressure Vessel Engineering, Ltd.

2"3000# Cplg N-E

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 3

ID Number: N-E

Vessel Number: Sample Vessel 5

Mark Number: N-E

Date Printed: 11/20/2008

Nozzle Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	0.00 PSI	Nozzle Efficiency (E):	70 %
Nozzle Material:	SA-182 F304 <=5", High	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	HA-1
External Projection:	1.0000 in.	Allowable Stress at Design Temperature (S _n):	18600 PSI
		Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0000 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle ID (new):	2.0970 in.	Nozzle Wall Thickness(new):	0.2730 in.
Nozzle ID (corroded):	2.0970 in.	Nozzle Wall Thickness(corroded):	0.2730 in.
Outer "h" Limit:	0.6825 in.	Upper Weld Leg Size(Weld 41):	0.3130 in.
OD, Limit of Reinforcement:	4.6430 in.	Outside Groove Weld Depth:	0.2730 in.

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F


Material exempt from impact testing per UCS-66(b), stress ratio <= 0.35

Host Component: Flange 2 - Cover Flange

Material:	SA-240 304, Low	Host Flange wall thickness(new):	1.0000 in.
Material Stress(S _v):	14400 PSI	Host Flange wall thickness(corroded):	1.0000 in.

Nozzle Detail Information

Abutting Groove



Upper Weld Leg Size(Weld 41):	0.3130 in.
Nozzle Wall Thickness(t _n):	0.2730 in.
Outside Groove Weld Depth:	0.2730 in.

Nozzle abuts the vessel, attached by a groove weld.
 Nozzle is adequate for UG-45 requirements.
 Opening is adequately reinforced for Internal Pressure.
 Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.
 Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

2"3000# Cplg N-E

Job No: PVE-Sample5
Number: 3
ID Number: N-E

Vessel Number: Sample Vessel 5
Mark Number: N-E

Date Printed: 11/20/2008

Required Host Flange Thickness per Paragraph UG-39(b)(1)

$$t_r = G * \sqrt{\frac{CP}{SE} + \frac{1.9 W_{m1} h_G}{SE G^3}} = 12.4800 * \sqrt{\frac{0.3000 * 200.00}{14400 * 1} + \frac{1.9 * 25923 * 1.1350}{14400 * 1 * 12.4800^3}} = \mathbf{0.9798 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{PR_n}{SE - 0.6P} = \frac{200.00 * 1.0485}{18600 * 1 - 0.6 * 200.00} = \mathbf{0.0113 \text{ in.}}$$

Strength Reduction Factors

$$fr_2 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{14400}, 1.0000\right) = 1.0000 \quad fr_3 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{14400}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PR_n}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{200.00 * 1.0485}{18600 * 0.70 - 0.6 * 200.00} + 0.0000 + 0.0000 = \mathbf{0.0163 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = G * \sqrt{\frac{CP}{SE} + \frac{1.9 W_{m1} h_G}{SE G^3}} + Ca + \text{ext. Ca} = 12.4800 * \sqrt{\frac{0.3000 * 200.00}{14400 * 1} + \frac{1.9 * 25923 * 1.1350}{14400 * 1 * 12.4800^3}} + 0.0000 + 0.0000 = \mathbf{0.9798 \text{ in.}}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + Ca + \text{ext. Ca} = \mathbf{0.1776 \text{ in.}}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = \mathbf{0.1776 \text{ in.}}$$

Wall thickness = $t_n = \mathbf{0.2730}$ is greater than or equal to UG-45 value of $\mathbf{0.1776}$

Pressure Vessel Engineering, Ltd.

2"3000# Cplg N-E

Job No: PVE-Sample5
Number: 3
ID Number: N-E

Vessel Number: Sample Vessel 5
Mark Number: N-E

Date Printed: 11/20/2008

Nozzle Weld Strength Calculations

Attachment Weld Strength per Paragraph UW-16

Weld 41 tmin = smaller of 0.75, t, or tn = smaller of 0.75, 1.0000, or 0.2730 = **0.2730 in.**

Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.1911}{0.7} = \mathbf{0.2730 \text{ in.}}$

Weld 41, actual weld leg = **0.3130 in.**

Unit Stresses per Paragraphs UG-45(c) and UW-15

Groove weld in shear = 0.60 * Groove Material Stress = 0.60 * 14400 = **8640 PSI**

Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 14400 = **7056 PSI**

Strength of Connection Elements

Groove weld in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Groove weld in shear unit stress} = \frac{1}{2} * \pi * 2.3700 * 0.2730 * 8640 = \mathbf{8780 \text{ lb.}}$

Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 2.6430 * 0.3130 * 7056 = \mathbf{9160 \text{ lb.}}$

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (b)

W = (A - A1) Sv = (1.0273 - 0.0514) * 14400 = **14100 lb.**

W1-1 = (A2 + A5 + A41 + A42) * Sv = (0.3572 + 0.0000 + 0.0980 + 0.0000) * 14400 = **6550 lb.**

W2-2 = (A2 + A41) Sv = (0.3572 + 0.0980) * 14400 = **6550 lb.**

Check Strength Paths

Path 1-1 = Upper fillet in shear + Groove weld in shear = 9160 + 8780 = **17940 lb.**

Path 2-2 = Upper fillet in shear + Groove weld in shear = 9160 + 8780 = **17940 lb.**

Pressure Vessel Engineering, Ltd.

2" Heavy Ferrule Nozzle B

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 4

ID Number: N-B

Vessel Number: Sample Vessel 5

Mark Number: N-B

Date Printed: 11/20/2008

Nozzle Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	0.00 PSI	Nozzle Efficiency (E):	70 %
Nozzle Material:	SA-479 304, High	Joint Efficiency (E ₁):	1.00
		Factor B Chart:	HA-1
External Projection:	1.5000 in.	Allowable Stress at Design Temperature (S _n):	18600 PSI
Internal Projection:	0.0000 in.	Allowable Stress at Ambient Temperature:	20000 PSI
Inside Corrosion Allowance:	0.0000 in.	Correction Factor (F):	1.00
External Corrosion Allowance:	0.0000 in.	Nozzle Path:	None
Nozzle ID (new):	1.8700 in.	Nozzle Wall Thickness(new):	0.1610 in.
Nozzle ID (corroded):	1.8700 in.	Nozzle Wall Thickness(corroded):	0.1610 in.
Outer "h" Limit:	0.4025 in.	Upper Weld Leg Size(Weld 41):	0.1880 in.
Internal "h" Limit:	0.4025 in.	Internal Weld Leg Size(Weld 43):	0.0000 in.
OD, Limit of Reinforcement:	3.7400 in.	Outside Groove Weld Depth:	0.1880 in.

Minimum Design Metal Temperature

Minimum Design Metal Temperature: -20 °F

Material exempt from impact testing per UCS-66(b), stress ratio <= 0.35

Host Component: Shell 2 - Shell 2 - thin shell

Material:	SA-240 304, High	Shell wall thickness(new):	0.1880 in.
Material Stress(S _v):	18600 PSI	Shell wall thickness(corroded):	0.1880 in.

Nozzle Detail Information

Backing strip if used may be removed after welding




Fig. UW-16.1 (c)

Upper Weld Leg Size(Weld 41): 0.1880 in.

Nozzle Wall Thickness(t_n): 0.1610 in.

Outside Groove Weld Depth: 0.1880 in.

Nozzle passes through the vessel, attached by a groove weld.

Nozzle is adequate for UG-45 requirements.

Opening is adequately reinforced for Internal Pressure.

Reinforcement calculations are not required per UG-36(c)(3)(a) See Uw-14 for exceptions.

Weld Strength Paths are adequate.

Pressure Vessel Engineering, Ltd.

2" Heavy Ferrule Nozzle B

Job No: PVE-Sample5
Number: 4
ID Number: N-B

Vessel Number: Sample Vessel 5
Mark Number: N-B

Date Printed: 11/20/2008

Required Shell Thickness per Paragraph UG-37(a)

$$t_r = \frac{PR_o}{SE + 0.4P} = \frac{200.00 * 6.3750}{18600 * 1 + 0.4 * 200.00} = \mathbf{0.0683 \text{ in.}}$$

Nozzle Required Thickness Calculations

Required Nozzle Thickness for Internal Pressure per Paragraph UG-37(a)

$$t_{rn} = \frac{PR_n}{SE - 0.6P} = \frac{200.00 * 0.9350}{18600 * 1 - 0.6 * 200.00} = \mathbf{0.0101 \text{ in.}}$$

Strength Reduction Factors

$$fr1 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000 \quad fr2 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000$$

$$fr3 = \min\left(\frac{S_n}{S_v}, 1.0000\right) = \min\left(\frac{18600}{18600}, 1.0000\right) = 1.0000$$

UG-45 Thickness Calculations

Nozzle Thickness for Pressure Loading (plus corrosion) per Paragraph UG-45(a)

$$t = \frac{PR_n}{SE - 0.6P} + Ca + \text{ext. Ca} = \frac{200.00 * 0.9350}{18600 * 0.70 - 0.6 * 200.00} + 0.0000 + 0.0000 = \mathbf{0.0145 \text{ in.}}$$

Nozzle Thickness for Internal Pressure (plus corrosion) per Paragraph UG-45(b)(1)

$$t = \frac{PR_o}{SE + 0.4P} + Ca + \text{ext. Ca} = \frac{200.00 * 6.3750}{18600 * 1 + 0.4 * 200.00} + 0.0000 + 0.0000 = \mathbf{0.0683 \text{ in.}}$$

Minimum Thickness of Standard Wall Pipe (plus corrosion) per Paragraph UG-45(b)(4)

$$t = \text{minimum thickness of standard wall pipe} + Ca + \text{ext. Ca} = \mathbf{0.1347 \text{ in.}}$$

Nozzle Minimum Thickness per Paragraph UG-45(b)

$$t = \text{Smallest of UG-45(b)(1) or UG-45(b)(4)} = \mathbf{0.0683 \text{ in.}}$$

Wall thickness = $t_n = \mathbf{0.1610}$ is greater than or equal to UG-45 value of $\mathbf{0.0683}$

Pressure Vessel Engineering, Ltd.

2" Heavy Ferrule Nozzle B

Job No: PVE-Sample5
Number: 4
ID Number: N-B

Vessel Number: Sample Vessel 5
Mark Number: N-B

Date Printed: 11/20/2008

Nozzle Weld Strength Calculations

Attachment Weld Strength per Paragraph UW-16

Weld 41 tmin = smaller of 0.75, t, or tn = smaller of 0.75, 0.1880, or 0.1610 = **0.1610 in.**

Weld 41 Leg min. = $\frac{(\text{smaller of } 0.25 \text{ or } (t_{\min} * 0.7)) + \text{ext. CA}}{0.7} = \frac{0.1127}{0.7} = \mathbf{0.1610 \text{ in.}}$

Weld 41, actual weld leg = **0.1880 in.**

Unit Stresses per Paragraphs UG-45(c) and UW-15

Nozzle wall in shear = 0.70 * Sn = 0.70 * 18600 = **13020 PSI**

Upper fillet, Weld 41, in shear = 0.49 * Material Stress = 0.49 * 18600 = **9114 PSI**

Vessel groove weld, in tension = 0.74 * Material Stress = 0.74 * 18600 = **13764 PSI**

Strength of Connection Elements

Nozzle wall in shear = $\frac{1}{2} * \pi * \text{mean nozzle diameter} * t_n * \text{Nozzle wall in shear unit stress} = \frac{1}{2} * \pi * 2.0310 * 0.1610 * 13020 = \mathbf{6680 \text{ lb.}}$

Upper fillet in shear = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{weld leg} * \text{upper fillet in shear unit stress} = \frac{1}{2} * \pi * 2.1920 * 0.1880 * 9114 = \mathbf{5900 \text{ lb.}}$

Groove Weld in Tension = $\frac{1}{2} * \pi * \text{Nozzle OD} * \text{groove depth} * \text{groove weld tension unit stress} = \frac{1}{2} * \pi * 2.1920 * 0.1880 * 13764 = \mathbf{8910 \text{ lb.}}$

Load to be carried by welds, per UG-41(b)(1) and Fig. UG-41.1 sketch (a)

W = [A - A1 + 2 tn fr1(E1t - Ftr)] Sv = [0.1277 - 0.2238 + 2 * 0.1610 * 1.0000 * (1.00 * 0.1880 - 1.0000 * 0.0683)] * 18600 = **-1070 lb.**

W1-1 = (A2 + A5 + A41 + A42) * Sv = (0.1215 + 0.0000 + 0.0353 + 0.0000) * 18600 = **2920 lb.**

W2-2 = (A2 + A3 + A41 + A43 + 2 tn t fr1) Sv = (0.1215 + 0.0000 + 0.0353 + 0.0000 + 2 * 0.1610 * 0.1880 * 1.0000) * 18600 = **4040 lb.**

W3-3 = (A2 + A3 + A5 + A41 + A42 + A43 + 2 tn t fr1) * Sv = (0.1215 + 0.0000 + 0.0000 + 0.0353 + 0.0000 + 0.0000 + 2 * 0.1610 * 0.1880 * 1.0000) * 18600 = **4040 lb.**

Check Strength Paths

Path 1-1 = Upper fillet in shear + Nozzle wall in shear = 5900 + 6680 = **12580 lb.**

Path 2-2 = Upper fillet in shear + Groove weld in tension + Inner fillet in shear = 5900 + 8910 + 0 = **14810 lb.**

Path 3-3 = Upper fillet in shear + Inner fillet in shear + Groove weld in tension = 5900 + 0 + 8910 = **14810 lb.**

Pressure Vessel Engineering, Ltd.

10" Inlet Flange

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 1

Vessel Number: Sample Vessel 5

Mark Number: F1

Date Printed: 11/20/2008

Loose Flange Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Material:	SA-240 304H, High	Factor B Chart:	HA-1
Outside Diameter (A):	14.7500 in.	Material Stress Hot(S _{fo}):	18600 PSI
Bolt Circle (C):	13.0000 in.	Material Stress Cold(S _{fa}):	20000 PSI
Flange Weight:	31.10 lb.	Flange I.D. (B):	10.8750 in.
		Flange MAWP (at design):	476.81 PSI

Minimum Design Metal Temperature

Material is exempt from impact testing per UHA-51(d)

Bolting Information

Material:	SA-193 Gr B8 <=3/4"	Material Stress Hot (S _b):	25000 PSI
Material Condition:	Class 2	Material Stress Cold (S _a):	25000 PSI
Bolt Size:	3/4"	Threads Per Inch:	10
Nominal Bolt Diameter (a):	0.7500 in.	Number of Bolts:	8
Bolt Hole Diameter:	0.8750 in.	Bolt Root Area:	0.3020 sq. in.

Gasket & Facing Information

Material:	Self energizing	Configuration:	Ring
Type:		Seating Stress (y):	200 PSI
O.D. Contact Face:	12.1250 in.	Gasket Width (N):	0.5000 in.
Factor m:	1.00		

Host Component: Nozzle 1 - 10" Inlet Nozzle C

Material:	SA-312 TP304 SMLS, High	Material Stress Hot (S _{no}):	18600 PSI
Inside Diameter:	10.0200 in.	Material Stress Cold (S _{na}):	20000 PSI
		Wall Thickness (t _n):	0.3650 in.

ASME Flange Calculations per Appendix 2

Gasket Seating Calculations(Table 2-5.2)

$$b_0 = \frac{N}{2} = \frac{0.5000}{2} = 0.2500 \text{ in.}$$

Since $b_0 \leq 1/4 \text{ in.}$, $b = b_0 = 0.2500 \text{ in.}$

$$G = \text{O.D. contact face} - N = 12.1250 - 0.5000 = 11.6250 \text{ in.}$$

Bolting is Adequate for Flange Design

Nominal Thickness is Adequate for Seating Conditions

Nominal Thickness is Adequate for Operating Conditions

Flange Thickness is Adequate for Flange Design

Flange Rigidity is Adequate.

Pressure Vessel Engineering, Ltd.

10" Inlet Flange

Job No: PVE-Sample5
Number: 1

Vessel Number: Sample Vessel 5
Mark Number: F1

Date Printed: 11/20/2008

Load and Bolting Calculations - Internal Pressure

The absolute value of effective pressure "P" is used for calculations.

$$P = \frac{16 M}{\pi G^3} + \frac{4 F_A}{\pi G^2} + P_{int} + \text{Static Head} = \frac{16 * 0}{3.14159 * 11.6250^3} + \frac{4 * 0}{3.14159 * 11.6250^2} + 200.00 + 1.00 = \mathbf{201.00 \text{ PSI}}$$

$$\text{Minimum } W_{m2} = \pi b G y = 3.14159 * 0.2500 * 11.6250 * 200 = \mathbf{1826 \text{ lb.}}$$

$$H = \frac{\pi}{4} G^2 P = \frac{3.14159}{4} * 11.6250^2 * 201.00 = \mathbf{21334 \text{ lb.}}$$

$$H_p = 2b\pi G m P = 2 * 0.2500 * 3.14159 * 11.6250 * 1.00 * 201.00 = \mathbf{3670 \text{ lb.}}$$

$$\text{Minimum } W_{m1} = H + H_p = 21334 + 3670 = \mathbf{25004 \text{ lb.}}$$

$$A_{m1} = \frac{W_{m1}}{S_b} = \frac{41173}{25000} = \mathbf{1.6469 \text{ sq. in.}}$$

$$A_{m2} = \frac{W_{m2}}{S_a} = \frac{1826}{25000} = \mathbf{0.0730 \text{ sq. in.}}$$

$$A_m = \text{Greater of } A_{m1} \text{ or } A_{m2} = \text{greater of } 1.6469 \text{ or } 0.0730 = \mathbf{1.6469 \text{ sq. in.}}$$

$$A_b = \text{Number of Bolts} * \text{Bolt Root Area} = 8 * 0.3020 = \mathbf{2.4160 \text{ sq. in.}}$$

$$W = \frac{(A_m + A_b) S_a}{2} = \frac{(1.6469 + 2.4160) * 25000}{2} = \mathbf{50786 \text{ lb.}}$$

Ab >= Am, Bolting is Adequate for Flange Design

Internal Pressure Moment Calculations - Operating Conditions

$$H_D = \frac{\pi}{4} B^2 P = \frac{3.1416}{4} * 10.8750^2 * 201.00 = \mathbf{18670 \text{ lb.}}$$

$$H_G = W_{m1} - H = 41173 - 21334 = \mathbf{19839 \text{ lb.}}$$

$$H_T = H - H_D = 21334 - 18670 = \mathbf{2664 \text{ lb.}}$$

$$h_D = \frac{C - B}{2} = \frac{13.0000 - 10.8750}{2} = \mathbf{1.0625 \text{ in.}}$$

$$h_G = \frac{C - G}{2} = \frac{13.0000 - 11.6250}{2} = \mathbf{0.6875 \text{ in.}}$$

$$h_T = \frac{h_D + h_G}{2} = \frac{1.0625 + 0.6875}{2} = \mathbf{0.8750 \text{ in.}}$$

$$M_D = H_D h_D = 18670 * 1.0625 = \mathbf{19837 \text{ in.-lb.}}$$

$$M_G = H_G h_G = 19839 * 0.6875 = \mathbf{13639 \text{ in.-lb.}}$$

$$M_T = H_T h_T = 2664 * 0.8750 = \mathbf{2331 \text{ in.-lb.}}$$

$$M_O = M_D + M_G + M_T = 19837 + 13639 + 2331 = \mathbf{35807 \text{ in.-lb.}}$$

Pressure Vessel Engineering, Ltd.

10" Inlet Flange

Job No: PVE-Sample5
Number: 1

Vessel Number: Sample Vessel 5
Mark Number: F1

Date Printed: 11/20/2008

Internal Pressure Moment Calculations - Gasket Seating

$$M_s = Wh_G = 50786 * 0.6875 = 34915 \text{ in.-lb.}$$

**Shape Constants
Calculated from Figure 2-7.1**

$$K = \frac{A}{B} = \frac{14.7500}{10.8750} = 1.3563$$

$$Y = \frac{1}{K - 1} \left(0.66845 + 5.71690 \frac{K^2 \log_{10} K}{K^2 - 1} \right) = \frac{1}{1.3563 - 1} \left(0.66845 + \left[5.7169 * \frac{1.3563^2 * \log_{10} 1.3563}{1.3563^2 - 1} \right] \right) = 6.5293$$

Bolt Spacing Calculations

C_f = 1, Correction factor not applied.

Internal Pressure Stress Calculations - Operating Conditions

$$S_T = \frac{Y C_f M_o}{B t^2} = \frac{6.5293 * 1.0000 * 35807}{10.8750 * 1.3750^2} = 11371 \text{ PSI}$$

Since S_T <= S_{fo}, nominal thickness is **ADEQUATE** for operating conditions.

Internal Pressure Stress Calculations - Gasket Seating

$$S_T = \frac{Y C_f M_s}{B t^2} = \frac{6.5293 * 1.0000 * 34915}{10.8750 * 1.3750^2} = 11088 \text{ PSI}$$

Since S_T <= S_{fa}, nominal thickness is **ADEQUATE** for seating conditions.

Internal Pressure Rigidity Index per Appendix 2-14 - Operating Conditions

$$J = \frac{109.4 M_o}{E t^3 \ln(K) K_L} = \frac{109.4 * 35807}{26.7 \times 10^6 * 1.3750^3 * \ln(1.3563) * 0.2} = 0.93$$

J <= 1, design meets Flange Rigidity requirements for Operating Conditions

Internal Pressure Rigidity Index per Appendix 2-14 - Seating Conditions

$$J = \frac{109.4 M_s}{E t^3 \ln(K) K_L} = \frac{109.4 * 34915}{28.3 \times 10^6 * 1.3750^3 * \ln(1.3563) * 0.2} = 0.85$$

J <= 1, design meets Flange Rigidity requirements for Seating Conditions

Internal Pressure Minimum Thickness = 1.3380 in.

Pressure Vessel Engineering, Ltd.

10" Inlet Flange

Job No: PVE-Sample5
Number: 1

Vessel Number: Sample Vessel 5
Mark Number: F1

Date Printed: 11/20/2008

Nominal Thickness Selected = **1.3750** in.

Pressure Vessel Engineering, Ltd.

Cover Flange

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 2

Vessel Number: Sample Vessel 5

Mark Number: F2

Date Printed: 11/20/2008

Blind Flange Design Information

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	0.00 PSI	Corrosion Allowance:	0.0000 in.
Material:	SA-240 304, Low	Factor B Chart:	HA-1
Outside Diameter (A):	12.7500 in.	Material Stress Hot(S_{fo}):	14400 PSI
Bolt Circle (C):	14.7500 in.	Material Stress Cold(S_{fa}):	20000 PSI
Flange Weight:	37.03 lb.	End Diameter (ID):	11.5000 in.
Head Factor C:	0.3000	Flange MAWP (at design):	201.31 PSI
Weld Efficiency:	100 %		

Minimum Design Metal Temperature

Material is exempt from impact testing per UHA-51(d)

Bolting Information

Material:	SA-193 Gr B8	Material Stress Hot (S_b):	14400 PSI
Material Condition:	Class 1	Material Stress Cold (S_a):	18800 PSI
Bolt Size:	3/4"	Threads Per Inch:	10
Nominal Bolt Diameter (a):	0.7500 in.	Number of Bolts:	6
		Bolt Root Area:	0.3020 sq. in.

Gasket & Facing Information

Material:	Asbestos with suitable binder	Configuration:	Ring
Type:	1/16 in. thick	Seating Stress (γ):	3700 PSI
O.D. Contact Face:	12.7500 in.	Gasket Width (N):	0.2700 in.
Factor m:	2.75		
Facing Sketch:	6	Seating Column:	Column II
Facing Width (w):	0.2700 in.		

ASME Flange Calculations per Appendix 2

Gasket Seating Calculations (Table 2-5.2)

Since $b_0 \leq 1/4$ in., $\mathbf{b} = b_0$ = **0.0338** in.

$\mathbf{G} = \text{O.D. contact face} - w = 12.7500 - 0.2700$ = **12.4800** in.

Bolting is Adequate for Flange Design

Nominal Thickness is Adequate for Seating Conditions

Nominal Thickness is Adequate for Operating Conditions

Flange Thickness is Adequate for Flange Design

Nominal Thickness Selected = **1.0000** in.

Pressure Vessel Engineering, Ltd.

Cover Flange

Job No: PVE-Sample5
Number: 2

Vessel Number: Sample Vessel 5
Mark Number: F2

Date Printed: 11/20/2008

Load and Bolting Calculations - Internal Pressure

The absolute value of effective pressure "P" is used for calculations.

$$P = \frac{16 M}{\pi G^3} + \frac{4 F_A}{\pi G^2} + P_{int} + \text{Static Head} = \frac{16 * 0}{3.14159 * 12.4800^3} + \frac{4 * 0}{3.14159 * 12.4800^2} + 200.00 + 0.00 = \mathbf{200.00 \text{ PSI}}$$

$$\text{Minimum } W_{m2} = \pi b G y = 3.14159 * 0.0338 * 12.4800 * 3700 = \mathbf{4903 \text{ lb.}}$$

$$H = \frac{\pi}{4} G^2 P = \frac{3.14159}{4} * 12.4800^2 * 200.00 = \mathbf{24465 \text{ lb.}}$$

$$H_p = 2b\pi G m P = 2 * 0.0338 * 3.14159 * 12.4800 * 2.75 * 200.00 = \mathbf{1458 \text{ lb.}}$$

$$\text{Minimum } W_{m1} = H + H_p = 24465 + 1458 = \mathbf{25923 \text{ lb.}}$$

$$A_{m1} = \frac{W_{m1}}{S_b} = \frac{25923}{14400} = \mathbf{1.8002 \text{ sq. in.}}$$

$$A_{m2} = \frac{W_{m2}}{S_a} = \frac{4903}{18800} = \mathbf{0.2608 \text{ sq. in.}}$$

$$A_m = \text{Greater of } A_{m1} \text{ or } A_{m2} = \text{greater of } 1.8002 \text{ or } 0.2608 = \mathbf{1.8002 \text{ sq. in.}}$$

$$A_b = \text{Number of Bolts} * \text{Bolt Root Area} = 6 * 0.3020 = \mathbf{1.8120 \text{ sq. in.}}$$

$$W = \frac{(A_m + A_b) S_a}{2} = \frac{(1.8002 + 1.8120) * 18800}{2} = \mathbf{33955 \text{ lb.}}$$

$$h_G = \frac{(C - G)}{2} = \frac{(14.7500 - 12.4800)}{2} = \mathbf{1.1350 \text{ in.}}$$

Ab >= Am, Bolting is Adequate for Flange Design

Thickness Calculations

$$\text{Operating Minimum } t = G \sqrt{\frac{CP}{SE} + \frac{1.9W_{m1}h_G}{SE G^3}} = 12.4800 * \sqrt{\frac{0.3000 * 200.00}{14400 * 1.00} + \frac{1.9 * 25923 * 1.1350}{14400 * 1.00 * 12.4800^3}} = \mathbf{0.9798 \text{ in.}}$$

$$\text{Seating Minimum } t = G \sqrt{\frac{1.9Wh_G}{SE G^3}} = 12.4800 * \sqrt{\frac{1.9 * 33955 * 1.1350}{20000 * 1.00 * 12.4800^3}} = \mathbf{0.5416 \text{ in.}}$$

$$\text{Minimum } t = \text{maximum}(0.9798, 0.5416) + CA = 0.9798 + 0.0000 = \mathbf{0.9798 \text{ in.}}$$

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

ASME Flange Design Information

Host	Description	Type	Size (in.)	Material	ASME Class	Material Group	MAP (PSI)
2" Inlet Nozzle A	ASME Flange 1	Slip-On	2	SA-182 F304	300	2.1	517.50

Pressure Vessel Engineering, Ltd.

Cone to Cylinder 1

Customer: **Pressure Vessel Engineering**
 Job No: PVE-Sample5
 Number: 1

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

**Cone-to-Cylinder Reinforcement
 Design Calculations for Small End Juncture
 Juncture is not a line of support**

Description:	Cone to Cylinder 1	Design Temperature:	350 °F
Design Pressure:	200.00 PSI	Static Head:	1.00 PSI
Axial Load in Compression (f ₂):	0 lb./in.		

Shell Design Information

8.03 OD Ferrule Advanced Coupling

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Shell Material:	SA-479 304, Low	Shell B Factor Table:	HA-1
Modulus of Elasticity (E _s):	26.7 10 ⁶ PSI	Material Stress (hot) (S _s):	14400 PSI
Shell Length (L _s):	1024.0000 in.	Material Stress (cold):	20000 PSI
Inside Radius:	3.9370 in.	Longitudinal Efficiency (E ₁):	70.00 %
Minimum Thickness (t):	0.0655 in.	Nominal Thickness (t _s):	0.0780 in.

Conical Reducer Design Information

Conical Reducer 1

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Cone Material:	SA-240 304, High	Cone B Factor Table:	HA-1
Modulus of Elasticity (E _c):	26.7 10 ⁶ PSI	Material Stress (hot) (S _c):	18600 PSI
Cone Surface Length (L _c):	5.5284 in.	Material Stress (cold):	20000 PSI
Cone Small End Diameter:	8.0300 in.	Cone Large End Diameter:	12.7500 in.
Nominal Thickness (t _c):	0.1875 in.	Minimum Thickness (t _r):	0.0682 in.
Cone Angle (α):	25 °		

Internal Pressure per Appendix 1-5

For $\frac{P}{S_s E_1} = \frac{201.00}{14400 * 0.70} = 0.019940$, maximum cone angle (Δ) = **12.5°**

Actual Cone Angle of 25° > maximum cone angle of 12.5°, reinforcement area requirements must be checked.

$Q_S = f_2 + \left(\frac{P R_S}{2} \right) = 0.00 + \left(\frac{201.00 * 3.9370}{2} \right) = \mathbf{395.67 \text{ lb./in.}}$

$Y = S_s E_s = 14400 * 26.7 * 10^6 = \mathbf{384480 \text{ } 10^6 \text{ PSI}^2}$

k = 1, No ring stiffener.

$A_{rS} = \left(\frac{k Q_S R_S}{S_s E_1} \right) \left(1 - \frac{\Delta}{\alpha} \right) \tan(\alpha) = \frac{1.0000 * 395.67 * 3.9370}{18600 * 0.70} \left(1 - \frac{12.5}{25.3} \right) 0.4721 = \mathbf{0.0369 \text{ sq. in.}}$

$A_{eS} = \frac{P_i}{4} \sqrt{R_S t_s} \left[(t_s - t) + \left(\frac{t_c - t_r}{\cos \alpha} \right) \right] = \frac{3.14159}{4} \sqrt{(3.9370 * 0.0780)} \left[(0.0780 - 0.0655) + \left(\frac{0.1875 - 0.0682}{0.9043} \right) \right] = \mathbf{0.0629 \text{ sq. in.}}$

$A_{eS} + A_s = 0.0629 + 0.0000 = \mathbf{0.0629 \text{ sq. in.}}$

**Cone area + shell area >= required area for internal reinforcement
 JUNCTURE PASSES**

Pressure Vessel Engineering, Ltd.

Cone to Cylinder 2

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 2

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

**Cone-to-Cylinder Reinforcement
Design Calculations for Small End Juncture
Juncture is not a line of support**

Description:	Cone to Cylinder 2	Design Temperature:	350 °F
Design Pressure:	200.00 PSI	Static Head:	1.00 PSI
Axial Load in Compression (f ₂):	0 lb./in.		

**Shell Design Information
8.03 OD Ferrule Advanced Coupling**

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Shell Material:	SA-479 304, Low	Shell B Factor Table:	HA-1
Modulus of Elasticity (E _S):	26.7 10 ⁶ PSI	Material Stress (hot) (S _S):	14400 PSI
Shell Length (L _S):	2.0000 in.	Material Stress (cold):	20000 PSI
Inside Radius:	3.9370 in.	Longitudinal Efficiency (E ₁):	70.00 %
Minimum Thickness (t):	0.0655 in.	Nominal Thickness (t _s):	0.0780 in.

**Conical Reducer Design Information
Conical Reducer 1**

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Cone Material:	SA-240 304, High	Cone B Factor Table:	HA-1
Modulus of Elasticity (E _C):	26.7 10 ⁶ PSI	Material Stress (hot) (S _C):	18600 PSI
Cone Surface Length (L _C):	5.5284 in.	Material Stress (cold):	20000 PSI
Cone Small End Diameter:	8.0300 in.	Cone Large End Diameter:	12.7500 in.
Nominal Thickness (t _C):	0.1875 in.	Minimum Thickness (t _r):	0.0682 in.
Cone Angle (α):	25 °		

Internal Pressure per Appendix 1-5

$$\text{For } \frac{P}{S_S E_1} = \frac{201.00}{14400 * 0.70} = 0.019940, \text{ maximum cone angle } (\Delta) = 12.5^\circ$$

Actual Cone Angle of 25° > maximum cone angle of 12.5°, reinforcement area requirements must be checked.

$$Q_S = f_2 + \left(\frac{P R_S}{2} \right) = 0.00 + \left(\frac{201.00 * 3.9370}{2} \right) = 395.67 \text{ lb./in.}$$

$$Y = S_S E_S = 14400 * 26.7 * 10^6 = 384480 \text{ 10}^6 \text{ PSI}^2$$

k = 1, No ring stiffener.

$$A_{rS} = \left(\frac{k Q_S R_S}{S_S E_1} \right) \left(1 - \frac{\Delta}{\alpha} \right) \tan(\alpha) = \frac{1.0000 * 395.67 * 3.9370}{18600 * 0.70} \left(1 - \frac{12.5}{25.3} \right) 0.4721 = 0.0369 \text{ sq. in.}$$

$$A_{eS} = \frac{P_i}{4} \sqrt{R_S t_s} \left[(t_s - t) + \left(\frac{t_c - t_r}{\cos \alpha} \right) \right] = \frac{3.14159}{4} \sqrt{(3.9370 * 0.0780)} \left[(0.0780 - 0.0655) + \left(\frac{0.1875 - 0.0682}{0.9043} \right) \right] = 0.0629 \text{ sq. in.}$$

$$A_{eS} + A_S = 0.0629 + 0.0000 = 0.0629 \text{ sq. in.}$$

**Cone area + shell area >= required area for internal reinforcement
JUNCTURE PASSES**

Pressure Vessel Engineering, Ltd.

Cone to Cylinder 3

Customer: **Pressure Vessel Engineering**

Job No: PVE-Sample5

Number: 3

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

**Cone-to-Cylinder Reinforcement
Design Calculations for Large End Juncture
Juncture is not a line of support**

Description:	Cone to Cylinder 3	Design Temperature:	350 °F
Design Pressure:	200.00 PSI	Static Head:	0.00 PSI
Axial Load in Compression (f ₁):	0 lb./in.		

**Shell Design Information
Shell 2**

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Shell Material:	SA-240 304H, High	Shell B Factor Table:	HA-1
Modulus of Elasticity (E _S):	26.7 10 ⁶ PSI	Material Stress (hot) (S _S):	18600 PSI
Shell Length (L _L):	15.5000 in.	Material Stress (cold):	20000 PSI
Inside Radius:	6.1870 in.	Longitudinal Efficiency (E ₁):	70.00 %
Minimum Thickness (t):	0.0974 in.	Nominal Thickness (t _S):	0.1880 in.

**Conical Reducer Design Information
Conical Reducer 1**

Design Pressure:	200.00 PSI	Design Temperature:	350 °F
Static Head:	1.00 PSI	Corrosion Allowance:	0.0000 in.
Cone Material:	SA-240 304, High	Cone B Factor Table:	HA-1
Modulus of Elasticity (E _C):	26.7 10 ⁶ PSI	Material Stress (hot) (S _C):	18600 PSI
Cone Surface Length (L _C):	5.5284 in.	Material Stress (cold):	20000 PSI
Cone Small End Diameter:	8.0300 in.	Cone Large End Diameter:	12.7500 in.
Nominal Thickness (t _C):	0.1875 in.	Minimum Thickness (t _r):	0.1077 in.
Cone Angle (α):	25 °		

Internal Pressure per Appendix 1-5

For $\frac{P}{S_S E_1} = \frac{200.00}{18600 * 0.70} = 0.015361$, maximum cone angle (Δ) = **30.0°**

Actual Cone Angle of 25° <= maximum cone angle of 30.0°, reinforcement not required for internal pressure.

**Maximum cone angle > Cone angle, reinforcement not needed for internal pressure
JUNCTURE PASSES**

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

MDMT Report by Components

Design MDMT is -20 °F

Component	Material	Curve	Pressure	MDMT
Outlet 8" Ferrule Nozzle D	SA-479 304, High			Exempt per UCS-66(b)
Shell 2 - thin shell	SA-240 304, High			Exempt per UCS-66(b)
10" Inlet Nozzle C	SA-312 TP304 SMLS,			Exempt per UCS-66(b)
10" Inlet Flange	SA-240 304H, High			Exempt per UHA-51(d)
2" Heavy Ferrule Nozzle B	SA-479 304, High			Exempt per UCS-66(b)
thick shell	SA-312 TP304 SMLS,			Exempt per UHA-51(d)
Conical Reducer 1	SA-240 304, High			Other Exemption
2" Inlet Nozzle A	SA-312 TP304 SMLS,			Exempt per UCS-66(b)
Cover Flange	SA-240 304, Low			Exempt per UHA-51(d)
2"3000# Cplg N-E	SA-182 F304 <=5", Hig			Exempt per UCS-66(b)

The required design MDMT of -20 °F has been met or exceeded for the calculated MDMT values.

ASME Flanges Are Not Included in MDMT Calculations.

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
 Job No: PVE-Sample5

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

MAWP Report by Components

<u>Component</u>	<u>Design Pressure</u>	<u>Static Head</u>	<u>Vessel MAWP New & Cold UG-98(a)</u>	<u>Component MAWP Hot & Corroded UG-98(b)</u>	<u>Vessel MAWP Hot & Corroded UG-98(a)</u>
Outlet 8" Ferrule Nozzle D	200.00 PSI	1.00 PSI	331.85 PSI	309.55 PSI	308.55 PSI
Shell 2 - thin shell	200.00 PSI	1.00 PSI	341.24 PSI	318.29 PSI	317.29 PSI
10" Inlet Nozzle C	200.00 PSI	1.00 PSI	341.24 PSI	318.29 PSI	317.29 PSI
10" Inlet Flange	200.00 PSI	1.00 PSI	NC	476.81 PSI	475.81 PSI
2" Heavy Ferrule Nozzle B	200.00 PSI	0.00 PSI	597.00 PSI	555.21 PSI	555.21 PSI
thick shell	200.00 PSI	1.00 PSI	1664.83 PSI	1549.16 PSI	1548.16 PSI
Conical Reducer 1	200.00 PSI	1.00 PSI	375.37 PSI	350.02 PSI	349.02 PSI
2" Inlet Nozzle A	200.00 PSI	1.00 PSI	660.56 PSI	615.25 PSI	614.25 PSI
ASME Flange Class: 300 Gr:2.1		1.00 PSI	719.00 PSI	517.50 PSI	516.50 PSI
Cover Flange	200.00 PSI	0.00 PSI	262.82 PSI	201.31 PSI	201.31 PSI
2"3000# Cplg N-E	200.00 PSI	0.00 PSI	289.37 PSI	208.34 PSI	208.34 PSI

NC = Not Calculated Inc = Incomplete

Summary

Component with the lowest vessel MAWP(New & Cold) : **Cover Flange**
 The lowest vessel MAWP(New & Cold) : **262.82 PSI**

Component with the lowest vessel MAWP(Hot & Corroded) : **Cover Flange**
 The lowest vessel MAWP(Hot & Corroded) : **201.31 PSI**

Pressures are exclusive of any external loads.

Flange pressures listed here do not consider external loadings

Pressure Vessel Engineering, Ltd.

Customer: **Pressure Vessel Engineering**
Job No: PVE-Sample5

Vessel Number: Sample Vessel 5

Date Printed: 11/20/2008

Summary Information

	<u>Dry Weight</u>	<u>Flooded Weight</u>
Shell	67.95 lb.	153.85 lb.
Conical Reducer	9.62 lb.	23.99 lb.
Nozzle	17.14 lb.	17.14 lb.
Flange	68.13 lb.	68.13 lb.
ASME Flange	7.00 lb.	7.00 lb.
Totals	<hr/> 169.83 lb.	<hr/> 270.11 lb.

	<u>Volume</u>
Shell	10.28 Gal.
Conical Reducer	1.72 Gal.
Nozzle	1.68 Gal.
Totals	<hr/> 13.68 Gal.

	<u>Area</u>
Shell	5.76 Sq. Ft.
Conical Reducer	1.25 Sq. Ft.
Nozzle	2.67 Sq. Ft.
Totals	<hr/> 9.68 Sq. Ft.

Hydrostatic Test Information Par. UG-99(b)

Gauge at Top

Calculated Test Pressure: **279.57 PSI**

Specified Test Pressure: **260.00 PSI**

This calculation assumes one chamber.

This calculation is limited by the lowest component pressure per chamber.